


Room: 32	Block: Main	Floor level: External
-----------------	--------------------	------------------------------

Item Details

Item number: 025	Sample number: 226/361	
Item: Asbestos cement roof tile(s)		
Asbestos content: Chrysotile		
Comments: Not applicable.		

Approximate extent: 700 sq m	Material score: 5
Priority: Low	Licensable: No (see appendix III)
Surface treatment: Unencapsulated asbestos cement	Condition: Minor scratches
Accessibility: Low	Recommendations: Monitor condition

Management Detail

Previous audit date:
Action taken:
Date:

Re audit date:
Removal contractor:
Consultant / analyst: