

<i>Item No.</i>	<i>Floor level</i>	<i>Block Name</i>	<i>Location</i>	<i>Item</i>	<i>Asbestos content</i>	<i>Extent</i>	<i>Material Risk</i>	<i>Recommendation</i>
004	0 - Ground	Main	02	Asbestos bitumen sink pad(s)	Chrysotile	<1 sq m	4	Label & monitor condition
007	0 - Ground	Main	08	Asbestos thermoplastic floor tile(s)	Chrysotile	4 sq m	4	Label & monitor condition
009	0 - Ground	Main	12	Asbestos thermoplastic floor tile(s)	Chrysotile	4 sq m	3	Label & monitor condition
010	0 - Ground	Main	13	Asbestos thermoplastic floor tile(s)	Chrysotile	4 sq m	3	Label & monitor condition
012	0 - Ground	Main	14	Asbestos thermoplastic floor tile(s)	Chrysotile	5 sq m	3	Label & monitor condition
021	01 - First	Main	25	Asbestos insulating board panels to wall(s)	Amosite	4 sq m	7	Encapsulate, label & monitor condition (or remove as part of planned works)
022	01 - First	Main	25	Asbestos cement flue	Chrysotile	10 linear metres	5	Label & monitor condition
025	External	Main	32	Asbestos cement roof tile(s)	Chrysotile	700 sq m	5	Monitor condition